

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 183Date: 23.06.2025

It is certified that an inspection team headed by Shubhamkar Kumar Biswas
 (Name of Officers with designation) from Research Assistant (Chemist), P.H.Div, Ara.
 (Name of Department/ Office) inspected the Arrah Central School, Hadiyabad, Garhani

Bhojpur. (Name & Address of the school) 23-06-25 (date of inspection) and found that the
Arrah Central School (Name of school) has safe drinking water facilities for the students and
 members of staff of the institution and is maintaining the hygienic sanitation condition in the school
 building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of One year.

Signature with Seal:

Name

Designation

Name & Address of the Office /Department:

To

Arrah Central School
Hadiyabad, Garhani, Bhojpur.

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

सेवा में,

कार्यपालक अभियंता ।.

लोक स्वास्थ्य समिती, आगा

झाण - उचित माध्यम।

विषय - जल जाँच रिपोर्ट प्रस्तुत करने हेतु।

महोदय,

निवेदनपूर्वक सूचित किया है, कि Central School,
Hadliya Bad, Anarhant (Bhairpur) का जल
जाँच कर, जाँचीपान, जाँच रिपोर्ट अक्टूबर
के अंतर्लोकार्थ प्रस्तुत कर रहा है।

आपका विश्वासी

गुर्नक राम (विश्वाम)

श्रीविश्वाम,

(स्वामिजी)

दिनांक - 23/06/25

Government of Bihar
Public Health Engineering Department
Monthly Water Quality Monitoring Report


District Name : Bhojpur
Sample Collected SELF

Division Name: P.H. Division, Ara

Date of Sampling :- 21.06.2025
Date of Testing :- 23.06.2025

S	Block	Panchayat	Village	Location of Source	Ward No.	Parameters															Remarks
						pH	Turb	EC	TDS	TH	Ca	Mg	Cl	Alka	Fe	NO ₃	SO ₄	F	As	Total Coli	
1	ARA	-	-	ARRAH CENTRAL SCHOOL HADIYABAD ;GARHANI (BHOJPUR)	-	8.06	0.4	441	287	260	35.27	41.79	19.99	272	0.21	NT	NT	NT	B.D.L	NEGATIVE	Safe
Permissible Limit in absence of alternative source						6.5-8.5	1	-	500	200	75	30	250	200	1	45	200	1	0.01	-	
						NR	5	-	2000	600	200	100	1000	600	NR	NR	400	1.5	NR	-	

*NT = Not Tested, BDL=Below Detection Limit


 Research Assistant
 (Chemist)
 P.H. Division, Ara